

Village of Caseyville

Consumer Confidence Report

2022 Annual Water Quality Report

This report is designed to inform you about the quality of water we delivered to you over the past year. If you have any questions about this report or concerning your water utility, please contact our Public Works Superintendent Brian Rader at (618) 344-1234 or attend any of our regularly scheduled meetings. They are held at 7:00 p.m. on the first and third Wednesdays of each month at the Caseyville Village Hall at 909 South Main St. Caseyville. **Paper copies available are at Village Hall.**

The Village of Caseyville purchases your water from Illinois American Water Company. This water is piped from the East St. Louis Water Treatment Plant which receives water from the Mississippi River. A source water assessment for the East St. Louis system has been completed by the Illinois EPA and a copy is available upon request by calling Sam Saucier, Water Quality Supervisor, at 618-707-1913. IEPA considers all surface water sources of community water supply to be susceptible to potential pollution problems, hence, the reason for mandatory treatment for all surface water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration, and disinfection.

To view a summary version of the completed Source Water Assessments you may access the IEPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Caseyville is responsible for providing high-quality water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Village of Caseyville routinely monitors for contaminants in your drinking water according to federal and state laws. The first table in this report shows the results of Illinois American's monitoring for the period of January 1st to December 31st, 2022 at its East St. Louis supply. The second table includes the system monitoring data for the Village of Caseyville.

Illinois American Water – East St. Louis

Regulated Substances Detected

Regulated Substances (Measured in the water leaving the treatment facility)

Substance (units)	Year Sampled	MCLG	MCL	Highest Level Detected	Range of Detections	Compliance Achieved	Typical Source
Atrazine (ppb)	2022	3	3	.8	0 – 0.8	Yes	Runoff from herbicide used on row crops
Arsenic (ppb)	2022	0	10	1	0 – 1	Yes	
Fluoride (ppm) ¹	2022	4	4	.8	0.78 – 0.78	Yes	Water additive that promotes strong teeth
Nitrate (ppm) ² [measured as Nitrogen]	2022	10	10	4	1.11 – 4.18	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Combined Radium 226/228 (pCi/L)	2020	0	5	1.29	0.977-1.29	Yes	Erosion of natural deposits
Beta/photon emitters (pCi/L)	2014	0	50	4.4	S	Yes	Decay of natural and man-made deposits
Gross alpha emitters (pCi/L)	2020	0	15	2.84	.24–2.84	Yes	Erosion of natural deposits
Xylenes	2018	10	10	.0007	0 - .0007	Yes	Discharge from petroleum factories; Discharge from chemical factories

¹ Fluoride is added to the water supply to help promote strong teeth. The Illinois Department of Public Health recommends an optimal fluoride level of 0.7 mg/L.

² Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider. The value in the "amount detected" column is the maximum detected for the year.

Other Compounds (Measured in the distribution system or in the water leaving the treatment facility)

Substance (units)	Year Sampled	MCLG/MRDLG	MCL/MRDL	Highest Level Detected	Range of Detections	Compliance Achieved	Typical Source
TTHMs [Total trihalomethanes] (ppb)	2022	NA	80	33	17.5 – 32.8	Yes	By-product of drinking water chlorination
HAAs [Haloacetic acids] (ppb)	2022	NA	60	23	8.6 – 30.5	Yes	By-product of drinking water chlorination
Chloramines (ppm) ³	2022	4	4	2.9	2.0 - 3.0	Yes	Water additive used to control microbes
TOC [Total organic carbon] (removal factor) ⁴	2015	NA	TT Removal □ □ 1.0	1.5	0.7 – 1.9	Yes	Naturally present in the environment

³ Chlorine and chloramines are disinfecting agents added to control microbes that otherwise could cause waterborne diseases or other water quality concerns. Most water systems in Illinois are required by law to add either chlorine or chloramines. Levels well in excess of the MRDL could cause irritation of the eyes or nose in some people. The values reported reflect multiple locations in the service area. At the East St. Louis facility, chloramines are used the majority of the year. Chloramines are a disinfectant made from combining chlorine and ammonia.

⁴ Total organic carbon (TOC) has no health effects. However, TOC provides a means for the formation of disinfection by-products. One way to minimize disinfection by-product formation is to remove a specific percentage of the TOC present in the source water. The numbers in the amount detected and range columns are the TOC removal factors, where the removal factor is defined as the actual percent TOC removal divided by the required percent removal. A value of 1.0 or greater in the amount detected column indicates that compliance with the removal requirement was achieved.

Turbidity⁵ (Measured in water leaving the treatment facility)

Substance (units)	Year Sampled	MCLG	MCL	Highest Level Detected	Range of Detections	Compliance Achieved	Typical Source
Turbidity (NTU) (%<0.3 NTU)	2022	NA	0.3 NTU	100%		Yes	Soil runoff
Turbidity (NTU)	2022	NA	1 NTU max	0.3 NTU	NA	Yes	Soil runoff

⁵ Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The treatment technique requires that at least 95% of routine samples are less than or equal to 0.3 NTU, and no sample exceeds 1 NTU. We are reporting the percentage of all readings meeting the standard of 0.3 NTU, plus the single highest reading for the year.

Lead and Copper⁶ (Collected at customers' taps)

Substance (units)	Year Sampled	MCLG	Action Level	90th Percentile	Number of Samples Collected	Number of Samples Above Action Level	Compliance Achieved	Typical Source
Copper (ppm)	2022	1.3	1.3	0.723		0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb) ⁷	2022	0	15	1		0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits

⁶ Compliance with the Lead and Copper Rule (LCR) is determined by the levels of lead and copper found in samples taken from customers' taps. LCR requirements are met if the 90th percentile of all samples taken does not exceed the action level of 15 ppb for lead or 1.300 ppm for copper.

⁷ Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated levels of lead in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to two minutes before using tap water. Additional information is available from the EPA's Safe Drinking Water Hotline at 800-426-4791.

State Regulated Substances

Substance (units)	Year Sampled	MCLG	MCL	Highest Level Detected	Range of Detections	Compliance Achieved	Typical Source
Sodium (ppm) ⁸	2022	NA	NA	23	15.5 – 22.7	Yes	Erosion of naturally occurring deposits; Byproduct of home water softening.
Manganese	2021	150	150	20	0 – 20	Yes	Erosion of naturally occurring deposits

⁸ There is no state or federal MCL for sodium. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. If you are on a sodium-restricted diet, you should consult a physician about this level of sodium in the water.

Unregulated Substances⁹

Substance (units)	Year Sampled	Highest Level Detected	Range of Detections	Typical Source
Sulfate (ppm)	2015	38.1	37.4 – 38.1	Erosion of naturally occurring deposits

⁹ A maximum contaminant level (MCL) for this substance has not been established by either state or federal regulations, nor has mandatory health effects language. The purpose for monitoring this substance is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water, and whether future regulation is warranted. For the N-nitrosodimethylamine and the N-nitroso-pyrrolidine, in the amount detected column we are reporting the average, and in the Range of Detections column we are reporting the lowest and highest individual readings.

Unregulated Contaminant Monitoring Rule (UCMR4)¹⁰

Substance (units)	Year Sampled	Amount Detected (Average)	Range of Detections	Typical Source
2-Methoxyethanol (ppb)	2019	0.075	ND - 0.6	Used in a number of consumer products, such as synthetic cosmetics, perfumes, fragrances, hair preparations and skin lotions
Manganese (ppb)	2019	7.31	2.5 - 17	Naturally occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries, and fireworks; drinking water and wastewater treatment chemical; essential nutrient
Total Haloacetic Acids -10 (ppb) UCMR4	2019	21	11 - 49	By-product of drinking water disinfection
Total Haloacetic Acids	2019	18	9.4 - 38	By-product of drinking water disinfection
Total Haloacetic Acids	2019	2.9	0.9 - 12	By-product of drinking water disinfection

¹⁰ Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. The maximum contaminant level (MCL) for these substances has not been established by either state or federal regulations, nor has mandatory health effects language.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each and the system met all TOC removal requirements set by IEPA. TOC has no health effects but contributes to the formation of disinfection by-products. Reduction of TOC can help to minimize disinfection by-products.

PER – POLYFLUOROALKYL SUBSTANCES (PFASs)

Per- or polyfluoroalkyl substances (PFASs) are synthetic substances used in a variety of products, such as: stain resistant fabric, non-stick coatings, firefighting foam, paints, waxes, and cleaning products. They are also components in some industrial processes like electronic manufacturing and oil recovery. While the EPA has not developed drinking water standards for PFAS, Illinois American Water recognizes the importance of testing for these contaminants. Compounds detected are tabulated below, along with typical sources.

In 2021, our PWS was sampled as of the State of Illinois PFAS Statewide Investigation. Results from this sampling indicated PFAS were detected in our drinking water (above the health advisory level/below health advisory level) establish by the Illinois EPA. Follow up monitoring is being conducted. For more information about PFAS health advisories <http://www2.illinois.gov/epa/topics/water-quality/pfas-healthadvisory.aspx>

UNREGULATED PERFLUORINATED COMPOUNDS – Collected at the East St. Louis Treatment Plant

Parameter	Year Sampled	Units	Health-Based Guidance Level	Highest Result	Range Detected	Typical Source
Perfluorooctane Sulfonic Acid (PFOS)	2022	ppt	14	2.8	0 to 2.8	Manufactured chemical(s); used in household goods for stain, grease, heat and water resistance.
Perfluorooctanoic Acid (PFOA)	2022	ppt	2	2.4	0 to 2.4	Manufactured chemical(s); used in household goods for stain, grease, heat and water resistance.
Perfluorohexanoic Acid (PFHxA)	2022	ppt	560,000	3.6	0 to 3.6	Manufactured chemical(s); used in household goods for stains, grease, heat and water resistance.
Perfluorobutanesulfonic Acid (PFBS)	2022	ppt	2,100	4.6	0 to 4.6	Manufactured chemical(s); used in household goods for stains, grease, heat and water resistance.

The health based guidance levels are intended to be protective of all people consuming the water over a lifetime of exposure. It is important to understand that guidance levels are not regulatory limits for drinking water. Rather, the guidance levels are benchmarks against which sampling results are compared to determine if additional investigation or other response is necessary

Cryptosporidium

Cryptosporidium is a protozoan found in untreated surface waters throughout the United States (the organism is generally not present in a ground water source). Although filtration removes Cryptosporidium, the most commonly used filtration methods cannot guarantee 100% removal. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, people with severely weakened immune systems have a risk of developing life-threatening illness. We encourage such people to consult their doctors regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it is spread through means other than drinking water.

USEPA issued a new rule in 2006 that requires systems with higher Cryptosporidium levels in their source water to provide additional treatment.

In 2015, our monitoring of the Mississippi River raw untreated water indicated the presence of this organism. The Mississippi River cryptosporidium levels ranged from not detected to 0.698 oocysts/L, with an average of 0.078 oocysts/L. Although this organism is present, it is at levels low enough that no supplemental treatment is required by our facility per USEPA standards.

CASEYVILLE WATER QUALITY REPORT

Lead and Copper (Collected at customers' taps)

Substance (units)	Date Sampled	MCLG	Action Level AL	90 th Percentile	# Sites over Action Limit	Compliance Achieved	Typical Source
Copper (ppm)	2020	1.3	AL=1.3	0.243	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Compliance with the Lead and Copper Rule (LCR) is determined by the levels of lead and copper found in samples taken from customers' taps. LCR requirements are met if the 90th percentile of all samples taken does not exceed the action level of 15 ppb for lead or 1.300 ppm for copper.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated levels of lead in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to two minutes before using tap water. Additional information is available from the EPA's Safe Drinking Water Hotline 800-426-4791.

Disinfections/Disinfectant By-Products

Substance (units)	Date Sampled	MCLG	MCL (ppb)	Highest Level Detected	Range of Detections	Compliance Achieved	Typical Source
HAAS-Total Haloacetic Acids (ppb)	2022	N/A	60	27	6.4 – 20.1	Yes	By-product of drinking water chlorination
TTHM-Total trihalomethanes (ppb)	2022	N/A	80	42	16.1 – 59.7	Yes	By-product of drinking water chlorination
Chloramines (ppm)*	2022	MRDLG=4	MRDL=4	2.5	21.7 – 3.0	Yes	Water additive used to control microbes

* Chlorine and chloramines are disinfecting agents added to control microbes that otherwise could cause waterborne diseases or other water quality concerns. Most water systems in Illinois are required by law to add either chlorine or chloramines. Levels well in excess of the MRDL could cause irritation of the eyes or nose in some people. The values reported reflect multiple locations in the service area. Chloramines are a disinfectant made from combining chlorine and ammonia.

Unregulated Contaminant Monitoring Rule (UCMR4)

Substance (units)	Year Sampled	Amount Detected (Average)	Range of Detection	Likely Source of Contamination
Manganese (ppb)	2019	12.5	12.3 – 12.7	Naturally-occurring element; commercially available in combination with other elements and minerals; used in steel production; fertilizer, batteries and fireworks; drinking water and wastewater treatment chemical; essential nutrient
Total Haloacetic Acids ¹¹ (ppb)	2019	17.046	16.27 – 18.014	By-product of drinking water disinfection.

¹¹ Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. The maximum contaminant level (MCL) for these substances has not been established by either state or federal regulations, nor has mandatory health effects language.

VIOLATIONS:

No violations were recorded during 2022.

Definition of Terms

Non-Detects (ND) – laboratory analysis indicates that the contaminant is not present. **Parts per million (ppm) or Milligrams per liter (mg/l)** – one part per million corresponds to one minute in two years or a single penny in \$10,000. **Parts per billion (ppb) or Micrograms per liter** – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000. **Parts per Trillion (ppt) or Nanograms per liter** – One part substance per Trillion parts water. **Picocuries per liter (pCi/L)** – picocuries per liter is a measure of the radioactivity in water. **Millirems per year (mrem/yr)** – measure of radiation absorbed by the body. **Nephelometric Turbidity Unit (NTU)** – nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. **Action Level (AL)** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. **Treatment Technique (TT)** – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water. **Maximum Contaminant Level** – the Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. **Maximum Contaminant Level Goal** – the Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. **Maximum Residual Disinfectant Level** – the MRDL is the highest level of disinfectant routinely allowed in drinking water. Addition of a disinfectant is necessary for control of microbial contaminants. **Maximum Residual Disinfectant Level Goal** – the level of drinking water disinfectant below which there is no known or expected risk to health.

Your drinking water meets or exceeds all Federal and State requirements. “All sources of drinking water are subject to potential contamination by contaminants that are naturally occurring or are manmade. Those contaminants can be microbes, organic or inorganic chemicals, or radioactive materials.” All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline.

